

#145241#

Потребитель
Адрес потребителя
Номер абонента
Порядковый номер
Тип теплосчётчика
Заводской номер
Номер системы

ЛАНСАР, ООО, УК 7435
Левитана 63к3, Калининград
7435
8458
ТЭСМА-106
1240003
1

Ведомость регистрации параметров:

Дата	Q, МВт*ч	V1, м3	V2, м3	M1, т	M2, т	TRab	TNar, ч	Tmin	Tmax	Tdt	Ttn, ч	TekErr	t1, °C	t2, °C	p1, МПа	p2, МПа	TempNar, °C
24.07.2025	0,366	180,406	181,734	176,172	177,672	22,92	22,91	0	0	0	0	16	72	70	0	0	-
25.07.2025	0,371	185,984	187,281	181,703	183,156	24	24	0	0	0	0	16	71	70	0	0	-
26.07.2025	0,321	186,984	187,641	182,672	183,469	24	24	0	0	0	0	16	71	70	0	0	-
27.07.2025	0,339	186,672	187,734	182,344	183,562	24	24	0	0	0	0	16	71	70	0	0	-
28.07.2025	0,333	187,75	188,438	183,375	184,219	24	24	0	0	0	0	16	72	70	0	0	-
29.07.2025	0,371	186,5	188,891	182,188	184,719	24	24	0	0	0	0	16	72	70	0	0	-
30.07.2025	0,436	186,359	189,531	182	185,328	24	24	0	0	0	0	16	72	70	0	0	-
31.07.2025	0,443	186,312	189,406	181,984	185,234	24	24	0	0	0	0	16	72	70	0	0	-
01.08.2025	0,448	186,422	189,703	182,078	185,516	24	24	0	0	0	0	16	72	70	0	0	-
02.08.2025	0,43	186,047	189,047	181,734	184,891	24	24	0	0	0	0	16	71	69	0	0	-
03.08.2025	0,474	184,984	188,016	180,719	183,922	24	24	0	0	0	0	16	71	69	0	0	-
04.08.2025	0,433	185,703	188,469	181,391	184,328	24	24	0	0	0	0	16	72	70	0	0	-
05.08.2025	0,489	166,422	169,922	162,578	166,25	24	24	0	0	0	0	16	71	69	0	0	-
06.08.2025	0,501	149,203	153,75	145,766	150,453	24	24	0	0	0	0	16	71	68	0	0	-
07.08.2025	0,551	149,172	153,375	145,719	150,109	24	24	0	0	0	0	16	72	68	0	0	-
08.08.2025	0,493	148,5	152,344	145,062	149,062	24	24	0	0	0	0	16	71	69	0	0	-
09.08.2025	0,502	148,938	152,875	145,484	149,594	24	24	0	0	0	0	16	72	69	0	0	-
10.08.2025	0,541	152,234	155,953	148,672	152,578	24	24	0	0	0	0	16	72	69	0	0	-
11.08.2025	0,529	152,562	156,234	148,984	152,844	24	24	0	0	0	0	16	72	69	0	0	-
12.08.2025	0,488	148,516	151,938	145,125	148,734	24	24	0	0	0	0	16	71	68	0	0	-
13.08.2025	0,457	149,141	151,875	145,703	148,578	24	24	0	0	0	0	16	72	69	0	0	-
14.08.2025	0,436	149,203	152,062	145,781	148,812	24	24	0	0	0	0	16	71	68	0	0	-
15.08.2025	0,435	149,156	151,984	145,766	148,75	24	24	0	0	0	0	16	71	68	0	0	-
16.08.2025	0,411	149,109	151,891	145,734	148,656	24	24	0	0	0	0	16	71	68	0	0	-
17.08.2025	0,477	149,375	152,203	145,938	148,953	24	24	0	0	0	0	16	71	69	0	0	-
18.08.2025	0,439	149,25	152,203	145,844	148,953	24	24	0	0	0	0	16	71	68	0	0	-
19.08.2025	0,452	148,938	151,75	145,547	148,531	24	24	0	0	0	0	16	71	68	0	0	-
20.08.2025	0,449	149,141	152,016	145,75	148,781	24	24	0	0	0	0	16	71	68	0	0	-
21.08.2025	0,439	149,203	151,938	145,797	148,688	24	24	0	0	0	0	16	71	68	0	0	-
22.08.2025	0,449	149,375	152,219	145,953	148,953	24	24	0	0	0	0	16	71	68	0	0	-
23.08.2025	0,409	148,625	151,328	145,234	148,094	24	24	0	0	0	0	16	71	68	0	0	-
Итого:	13,712	5086,186	5173,751	4968,797	5061,389	742,92	742,91	0	0	0	0	0	0	0	0	0	0
Гкал	11,792																

Общее время работы системы, ч744

Период нормальной работы системы, ч742,91

Показания интеграторов:

Дата	Q, МВт*ч	V1, м3	V2, м3	M1, т	M2, т	TNar, ч	Ttn, ч
23.07.2025	2912,792	186031,094	198300,234	181268,969	194622,359	31464,41	754,27
23.08.2025	2926,504	191117,281	203473,984	186237,766	199683,75	32207,32	754,27

Подпись абонента

Представитель теплоснабжения

ТЕПЛОСЧЕТЧИКИ

МП «Калининградтеплосеть»

ОТЧЕТ ПРИНЯТ

27.08.2025 14:25:06