

Донского.23 Дет. обл. больница

Среднесуточные значения параметров теплопотребления
Тепловая система 1. Схема 2.9

Дата	Схема	Qo, Гкал	M1, т	M1R, т	dM, т	V1, м3	V1R, м3	t1, °C	t2, °C	dt1, °C	P1, МПа	P2, МПа	Траб.ТС, чч:мм	Тост.ТС, чч:мм	Траб.шт, чч:мм	Tmin, чч:мм	Tmax, чч:мм	Tdt, чч:мм	Тф, чч:мм	Тпуст.тр, чч:мм	Канальные НС	НС ТС
21.04.25	2.9	0,000	0,000	0,000	0,000	0,000	0,000	17,66	18,57	-0,91	0,082	0,085	00:00	24:00	00:00	00:00	00:00	24:00	00:00	00:00	0	1,2,F
22.04.25	2.9	1,877	57,633	0,000	0,000	58,755	0,000	64,63	26,37	38,26	0,302	0,288	14:20	09:40	14:20	00:00	00:00	09:40	00:00	00:00	0	1,2,F
23.04.25	2.9	3,073	96,253	0,000	0,000	98,216	0,000	66,39	34,42	31,97	0,448	0,421	23:06	00:54	23:06	00:00	00:00	00:00	00:54	00:00	0	F
24.04.25	2.9	0,000	0,000	0,000	0,000	0,000	0,000	25,67	27,16	-1,49	0,417	0,421	00:00	24:00	00:00	00:00	00:00	18:09	05:51	00:00	0	1,2,F
25.04.25	2.9	1,065	32,003	0,000	0,000	32,600	0,000	62,94	25,38	37,56	0,430	0,424	08:18	15:42	08:18	00:00	00:00	15:42	00:00	00:00	0	1,2,F
26.04.25	2.9	1,518	45,313	0,000	0,000	46,190	0,000	64,44	29,16	35,28	0,433	0,424	11:48	12:13	11:48	00:00	00:00	06:40	05:33	00:00	0	1,2,F
27.04.25	2.9	1,851	53,980	0,000	0,000	55,040	0,000	64,99	29,70	35,29	0,436	0,424	14:04	09:56	14:04	00:00	00:00	04:29	05:27	00:00	0	1,2,F
28.04.25	2.9	1,244	36,709	0,000	0,000	37,440	0,000	65,58	29,50	36,08	0,434	0,427	09:27	14:33	09:27	00:00	00:00	08:33	06:00	00:00	0	1,2,F
29.04.25	2.9	0,665	19,595	0,000	0,000	19,955	0,000	62,29	25,57	36,72	0,428	0,426	04:44	19:16	04:44	00:00	00:00	19:16	00:00	00:00	0	1,2,F
30.04.25	2.9	1,787	53,623	0,000	0,000	54,680	0,000	65,11	30,56	34,55	0,439	0,426	12:45	11:15	12:45	00:00	00:00	05:21	05:54	00:00	0	1,2,F
01.05.25	2.9	1,769	53,445	0,000	0,000	54,505	0,000	65,33	30,89	34,44	0,438	0,425	12:28	11:32	12:28	00:00	00:00	06:11	05:21	00:00	0	1,2,F
02.05.25	2.9	1,835	55,783	0,000	0,000	56,895	0,000	65,53	31,61	33,92	0,440	0,426	12:56	11:04	12:56	00:00	00:00	05:22	05:42	00:00	0	1,2,F
03.05.25	2.9	1,826	56,932	0,000	0,000	58,040	0,000	64,70	31,57	33,13	0,428	0,414	13:32	10:28	13:32	00:00	00:00	05:05	05:23	00:00	0	1,2,F
04.05.25	2.9	1,889	58,939	0,000	0,000	60,080	0,000	64,51	31,53	32,98	0,436	0,422	14:00	10:00	14:00	00:00	00:00	04:57	05:03	00:00	0	1,2,F
05.05.25	2.9	2,220	68,386	0,000	0,000	69,715	0,000	64,69	31,47	33,22	0,440	0,422	16:37	07:23	16:37	00:00	00:00	02:43	04:40	00:00	0	1,2,F
06.05.25	2.9	1,360	47,185	0,000	0,000	47,945	0,000	58,51	28,09	30,42	0,351	0,344	17:05	06:55	17:05	00:00	00:00	01:33	05:22	00:00	0	1,2,F
07.05.25	2.9	2,249	70,005	0,000	0,000	71,285	0,000	62,56	30,07	32,49	0,434	0,417	17:36	06:24	17:36	00:00	00:00	01:45	04:39	00:00	0	1,2,F
08.05.25	2.9	1,789	53,057	0,000	0,000	54,105	0,000	65,18	30,40	34,78	0,426	0,413	12:38	11:23	12:38	00:00	00:00	06:58	04:25	00:00	0	1,2,F
09.05.25	2.9	1,905	55,607	0,000	0,000	56,710	0,000	65,36	30,25	35,11	0,427	0,413	13:05	10:56	13:05	00:00	00:00	06:24	04:32	00:00	0	1,2,F
10.05.25	2.9	1,982	57,332	0,000	0,000	58,475	0,000	65,54	30,11	35,43	0,427	0,412	13:21	10:39	13:21	00:00	00:00	06:14	04:25	00:00	0	1,2,F
11.05.25	2.9	2,050	59,761	0,000	0,000	60,950	0,000	65,47	30,41	35,06	0,428	0,413	14:04	09:56	14:04	00:00	00:00	05:27	04:29	00:00	0	1,2,F
12.05.25	2.9	2,534	73,806	0,000	0,000	75,285	0,000	65,74	30,99	34,75	0,435	0,416	17:52	06:08	17:52	00:00	00:00	01:39	04:29	00:00	0	1,2,F
13.05.25	2.9	2,384	70,302	0,000	0,000	71,700	0,000	65,47	31,11	34,36	0,434	0,417	17:41	06:20	17:41	00:00	00:00	01:39	04:41	00:00	0	1,2,F
14.05.25	2.9	2,155	64,067	0,000	0,000	65,325	0,000	65,04	30,89	34,15	0,426	0,412	17:39	06:21	17:39	00:00	00:00	01:41	04:40	00:00	0	1,2,F
15.05.25	2.9	2,073	60,284	0,000	0,000	61,450	0,000	64,50	29,68	34,82	0,407	0,396	17:40	06:20	17:40	00:00	00:00	01:31	04:49	00:00	0	1,2,F
16.05.25	2.9	2,264	67,213	0,000	0,000	68,505	0,000	64,31	30,21	34,10	0,437	0,422	17:58	06:02	17:58	00:00	00:00	01:53	04:09	00:00	0	1,2,F
17.05.25	2.9	1,683	49,563	0,000	0,000	50,520	0,000	64,42	29,90	34,52	0,430	0,420	12:46	11:14	12:46	00:00	00:00	07:03	04:11	00:00	0	1,2,F
18.05.25	2.9	1,920	55,418	0,000	0,000	56,510	0,000	65,10	30,14	34,96	0,432	0,420	14:09	09:51	14:09	00:00	00:00	05:36	04:15	00:00	0	1,2,F
19.05.25	2.9	2,515	74,836	0,000	0,000	76,315	0,000	65,27	31,21	34,06	0,436	0,417	17:56	06:04	17:56	00:00	00:00	01:47	04:17	00:00	0	1,2,F
20.05.25	2.9	2,675	81,526	0,000	0,000	83,185	0,000	66,30	33,08	33,22	0,429	0,406	17:57	06:03	17:57	00:00	00:00	01:42	04:21	00:00	0	1,2,F
21.05.25	2.9	1,349	42,174	0,000	0,000	43,045	0,000	66,87	32,64	34,23	0,412	0,402	09:21	14:39	09:21	00:00	00:00	10:17	04:22	00:00	0	1,2,F

**Итоговые значения параметров теплоснабжения
Тепловая система 1. Схема 2.9**

Дата	Схема	Qo, Гкал	M1, т	M1R, т	dM, т	V1, м3	V1R, м3	t1, °C	t2, °C	dt1, °C	P1, МПа	P2, МПа	Траб.ТС, чч:мм	Тост.ТС, чч:мм	Траб.шт, чч:мм	Tmin, чч:мм	Tmax, чч:мм	Tdt, чч:мм	Тф, чч:мм	Тпуст.тр, чч:мм	Канальные НС	НС ТС
Итого	2.9	55,506	1670,729	0,000	0,000	1703,429	0,000	61,94	29,76	32,18	0,413	0,400	416:53	327:11	416:53	00:00	00:00	199:17	127:54	00:00	0	1,2,F
Среднее	2.9	1,791	53,894	0,000	0,000	54,949	0,000	61,94	29,76	32,18	0,413	0,400	13:27	10:33	13:27	00:00	00:00	06:26	04:08	00:00	---	---
На 21.04.25	Не исп.	0,000	0	0	0	0	0	0	0	0	0,000	0,000	00:00	00:00	00:00	00:00	00:00	00:00	00:00	00:00		
На 21.05.25	2.9	6792,255	257707,766	0,000	0,000	264075,250	0,000	66,87	32,64	34,23	0,412	0,402	36698:00	27467:21	36698:00	00:00	00:00	22856:42	4612:32	00:00	0	1,2,F

