



#51828#

Отчёт за период с 20.11.2023 по 20.12.2023.

Номер абонента 6852  
 Порядковый номер 8365  
 Тип теплосчётчика ТЭСМА-106  
 Заводской номер 3060404  
 Номер системы 1  
 Отчёт сформирован 21.12.2023

Ведомость регистрации параметров:

Дата	tнар, °C	Q, МВт×ч	V1, м3	V2, м3	M1, т	M2, т	TRab,	TNар, ч	Tmin,	Tmax,	Tdt,	Ttn, ч	TekErr,	t1, °C	t2, °C	p1, МПа	p2, МПа
21.11.2023	-1,1	0,183	6,112	6,046	5,951	5,973	24	24	0	0	0	0	0	77	50	0	0
22.11.2023	-2,3	0,174	5,566	5,505	5,42	5,441	24	24	0	0	0	0	0	77	49	0	0
23.11.2023	3,3	0,167	5,848	5,79	5,706	5,726	24	24	0	0	0	0	0	73	48	0	0
24.11.2023	3,5	0,181	6,957	6,902	6,792	6,822	24	24	0	0	0	0	0	72	50	0	0
25.11.2023	-0,2	0,179	6,214	6,148	6,054	6,074	24	24	0	0	0	0	0	76	50	0	0
26.11.2023	-2,4	0,163	5,299	5,241	5,157	5,178	24	24	0	0	0	0	0	78	50	0	0
27.11.2023	-7,5	0,183	5,547	5,478	5,393	5,411	24	24	0	0	0	0	0	80	50	0	0
28.11.2023	-7,3	0,217	6,983	6,895	6,782	6,803	24	24	0	0	0	0	0	81	53	0	0
29.11.2023	-6,5	0,206	6,558	6,475	6,371	6,389	24	24	0	0	0	0	0	81	53	0	0
30.11.2023	-5,4	0,199	6,221	6,144	6,044	6,065	24	24	0	0	0	0	0	0	0	0	0
01.12.2023	-	0,188	6,046	5,976	5,884	5,903	24	24	0	0	0	0	0	78	51	0	0
02.12.2023	-	0,163	5,521	5,459	5,376	5,393	24	24	0	0	0	0	0	77	51	0	0
03.12.2023	-	0,163	5,608	5,547	5,462	5,479	24	24	0	0	0	0	0	76	51	0	0
04.12.2023	-	0,185	6,498	6,427	6,33	6,348	24	24	0	0	0	0	0	76	51	0	0
05.12.2023	-	0,166	4,514	4,45	4,393	4,406	24	24	0	0	0	0	0	78	46	0	0
06.12.2023	-	0,177	4,745	4,676	4,608	4,624	24	24	0	0	0	0	0	81	48	0	0
07.12.2023	-	0,166	4,4	4,338	4,279	4,295	24	24	0	0	0	0	0	79	46	0	0
08.12.2023	-	0,181	4,92	4,849	4,78	4,798	24	24	0	0	0	0	0	80	48	0	0
09.12.2023	-	0,187	5,033	4,963	4,891	4,91	24	24	0	0	0	0	0	80	47	0	0
10.12.2023	-	0,176	4,93	4,867	4,798	4,817	24	24	0	0	0	0	0	78	46	0	0
11.12.2023	-	0,167	4,938	4,88	4,813	4,832	24	24	0	0	0	0	0	75	45	0	0
12.12.2023	-	0,144	4,376	4,325	4,27	4,285	24	24	0	0	0	0	0	73	45	0	0
13.12.2023	-	0,13	3,975	3,93	3,878	3,892	24	24	0	0	0	0	0	74	45	0	0
14.12.2023	-	0,146	4,17	4,119	4,062	4,079	24	24	0	0	0	0	0	76	46	0	0
15.12.2023	-	0,147	4,346	4,299	4,237	4,258	24	24	0	0	0	0	0	75	45	0	0
16.12.2023	-	0,123	3,986	3,947	3,898	3,914	24	24	0	0	0	0	0	70	42	0	0
17.12.2023	-	0,119	3,798	3,761	3,717	3,732	24	24	0	0	0	0	0	68	40	0	0
18.12.2023	-	0,116	3,718	3,681	3,641	3,652	24	24	0	0	0	0	0	68	40	0	0
19.12.2023	-	0,105	3,457	3,423	3,385	3,396	24	24	0	0	0	0	0	68	41	0	0
20.12.2023	-	0,125	4,186	4,146	4,096	4,109	24	24	0	0	0	0	0	69	42	0	0
Итого:	-2	4,926	154,47	152,687	150,468	151,004	720	720	0	0	0	0	-	73,13	45,63	0	0

Общее время работы системы 720 час.

Период нормальной работы системы 720 час.

Показания интеграторов:

Дата	Q, МВт×ч	V1, м3	V2, м3	M1, т	M2, т	TNар, ч	Ttn, ч
20.11.2023	146,943	10074,106	10119,898	9840,891	9955,104	41588,57	1,45
20.12.2023	151,869	10228,575	10272,582	9991,357	10106,11	42308,57	1,45

Подпись абонента

Представитель теплоснабжения