

Ведомость учета расхода воды
за период с 23.04.2025 по 23.05.2025

Потребитель: ООО Мастер
Адрес объекта: Громовой 105 (первая очередь)
МКТС: № 002611-2 Версия МКТС: 2.42

Дата	Трубопровод № 1				Трубопровод № 2				Трубопровод № 3			
	Объем V1, м3	Темп. °C	Давл. ати	Вр.раб час	Объем V2, м3	Темп. °C	Давл. ати	Вр.раб час	Объем V3, м3	Темп. °C	Давл. ати	Вр.раб час
23.04.25	83.84	60.3	4.0	24.00	74.20	54.3	4.0	24.00	0.00	---	---	0.00
24.04.25	84.09	60.2	4.0	24.00	74.11	54.1	4.0	24.00	0.00	---	---	0.00
25.04.25	84.75	59.8	4.0	24.00	73.72	53.5	4.0	24.00	0.00	---	---	0.00
26.04.25	83.91	59.8	4.0	24.00	74.02	53.5	4.0	24.00	0.00	---	---	0.00
27.04.25	84.22	59.7	4.0	24.00	74.05	53.3	4.0	24.00	0.00	---	---	0.00
28.04.25	83.78	59.9	4.0	24.00	74.25	53.7	4.0	24.00	0.00	---	---	0.00
29.04.25	84.19	59.8	4.0	24.00	73.84	53.5	4.0	24.00	0.00	---	---	0.00
30.04.25	83.34	59.7	4.0	24.00	74.13	53.5	4.0	24.00	0.00	---	---	0.00
01.05.25	83.63	59.7	4.0	24.00	74.25	53.6	4.0	24.00	0.00	---	---	0.00
02.05.25	83.53	59.6	4.0	24.00	74.22	53.5	4.0	24.00	0.00	---	---	0.00
03.05.25	82.69	59.3	4.0	24.00	73.89	53.1	4.0	24.00	0.00	---	---	0.00
04.05.25	83.28	59.2	4.0	24.00	73.58	52.9	4.0	24.00	0.00	---	---	0.00
05.05.25	82.88	59.0	4.0	24.00	72.75	52.7	4.0	24.00	0.00	---	---	0.00
06.05.25	82.31	58.7	4.0	24.00	72.08	52.1	4.0	24.00	0.00	---	---	0.00
07.05.25	82.91	58.2	4.0	24.00	71.55	51.7	4.0	24.00	0.00	---	---	0.00
08.05.25	81.50	58.2	4.0	24.00	71.81	51.6	4.0	24.00	0.00	---	---	0.00
09.05.25	81.16	58.0	4.0	24.00	71.98	51.2	4.0	24.00	0.00	---	---	0.00
10.05.25	82.69	57.6	4.0	24.00	71.52	51.0	4.0	24.00	0.00	---	---	0.00
11.05.25	81.53	58.0	4.0	24.00	71.56	51.5	4.0	24.00	0.00	---	---	0.00
12.05.25	81.28	58.1	4.0	24.00	71.64	51.5	4.0	24.00	0.00	---	---	0.00
13.05.25	81.81	58.0	4.0	24.00	71.42	51.7	4.0	24.00	0.00	---	---	0.00
14.05.25	82.66	57.9	4.0	24.00	71.16	51.2	4.0	24.00	0.00	---	---	0.00
15.05.25	82.44	57.8	4.0	24.00	71.03	51.5	4.0	24.00	0.00	---	---	0.00
16.05.25	82.91	57.4	4.0	24.00	71.13	51.2	4.0	24.00	0.00	---	---	0.00
17.05.25	81.00	57.0	4.0	24.00	70.95	50.8	4.0	24.00	0.00	---	---	0.00
18.05.25	82.09	57.1	4.0	24.00	70.80	50.9	4.0	24.00	0.00	---	---	0.00
19.05.25	81.63	57.4	4.0	24.00	71.30	51.2	4.0	24.00	0.00	---	---	0.00
20.05.25	82.03	57.4	4.0	24.00	71.05	51.3	4.0	24.00	0.00	---	---	0.00
21.05.25	81.06	57.5	4.0	24.00	70.55	51.3	4.0	24.00	0.00	---	---	0.00
22.05.25	80.56	57.3	4.0	24.00	70.05	51.4	4.0	24.00	0.00	---	---	0.00
23.05.25	80.59	57.2	4.0	24.00	70.02	51.3	4.0	24.00	0.00	---	---	0.00
Итого:	2560.28	58.6	4.0	744.00	2242.58	52.3	4.0	744.00	0.00	---	---	0.00

Показания МКТС (нарастающим итогом)

Дата	Объем V1, м3	Траб V1, ч	Объем V2, м3	Траб V2, ч	Объем V3, м3	Траб V3, ч
23.05.25 24:00	284129.31	110233.61	240021.58	110233.61	0.00	0.00
22.04.25 24:00	281569.03	109489.61	237779.00	109489.61	0.00	0.00
Итого:	2560.28	744.00	2242.58	744.00	0.00	0.00

Отчетный период: 744.00 ч Время откл. эл.-питания: 0.00 ч
 Время работы V1: 744.00 ч Время неисправности V1: 0.00 ч
 Время работы V2: 744.00 ч Время неисправности V2: 0.00 ч
 Время работы V3: 0.00 ч Время неисправности V3: 744.00 ч

Представитель
потребителя: _____

Представитель
поставщика: _____

Распечатано программой MktsPrint, версия: 1.3.1

