

Ведомость учета расхода воды
за период с 23.08.2024 по 23.09.2024

Потребитель: ООО Мастер
 Адрес объекта: Громовой 105 (первая очередь)
 МКТС: № 002611-2 Версия МКТС: 2.42

Дата	Трубопровод № 1				Трубопровод № 2				Трубопровод № 3			
	Объем V1, м3	Темп. °С	Давл. ати	Вр.раб час	Объем V2, м3	Темп. °С	Давл. ати	Вр.раб час	Объем V3, м3	Темп. °С	Давл. ати	Вр.раб час
23.08.24	84.20	61.0	4.0	24.00	76.58	55.3	4.0	24.00	0.00	---	---	0.00
24.08.24	84.58	61.0	4.0	24.00	76.42	55.5	4.0	24.00	0.00	---	---	0.00
25.08.24	84.05	61.0	4.0	24.00	76.36	55.6	4.0	24.00	0.00	---	---	0.00
26.08.24	81.39	60.9	4.0	24.00	73.00	55.4	4.0	24.00	0.00	---	---	0.00
27.08.24	85.06	61.0	4.0	24.00	76.55	55.5	4.0	24.00	0.00	---	---	0.00
28.08.24	84.84	61.0	4.0	24.00	76.53	55.6	4.0	24.00	0.00	---	---	0.00
29.08.24	80.67	61.0	4.0	24.00	72.44	55.8	4.0	24.00	0.00	---	---	0.00
30.08.24	87.13	61.1	4.0	24.00	79.19	55.9	4.0	24.00	0.00	---	---	0.00
31.08.24	87.19	61.0	4.0	24.00	78.89	55.7	4.0	24.00	0.00	---	---	0.00
01.09.24	87.39	61.0	4.0	24.00	78.39	55.7	4.0	24.00	0.00	---	---	0.00
02.09.24	86.63	61.0	4.0	24.00	78.58	55.7	4.0	24.00	0.00	---	---	0.00
03.09.24	86.39	61.0	4.0	24.00	78.42	55.8	4.0	24.00	0.00	---	---	0.00
04.09.24	85.89	61.0	4.0	24.00	78.56	55.8	4.0	24.00	0.00	---	---	0.00
05.09.24	85.94	61.0	4.0	24.00	78.27	55.8	4.0	24.00	0.00	---	---	0.00
06.09.24	85.30	61.0	4.0	24.00	78.33	55.8	4.0	24.00	0.00	---	---	0.00
07.09.24	84.78	61.0	4.0	24.00	78.38	55.8	4.0	24.00	0.00	---	---	0.00
08.09.24	85.63	61.0	4.0	24.00	78.06	55.8	4.0	24.00	0.00	---	---	0.00
09.09.24	85.28	61.0	4.0	24.00	78.20	55.8	4.0	24.00	0.00	---	---	0.00
10.09.24	85.78	61.0	4.0	24.00	77.97	55.6	4.0	24.00	0.00	---	---	0.00
11.09.24	84.97	61.0	4.0	24.00	77.91	55.5	4.0	24.00	0.00	---	---	0.00
12.09.24	85.53	61.0	4.0	24.00	77.78	55.4	4.0	24.00	0.00	---	---	0.00
13.09.24	86.19	61.0	4.0	24.00	77.89	55.1	4.0	24.00	0.00	---	---	0.00
14.09.24	86.03	61.0	4.0	24.00	78.03	55.1	4.0	24.00	0.00	---	---	0.00
15.09.24	86.25	61.0	4.0	24.00	77.97	55.1	4.0	24.00	0.00	---	---	0.00
16.09.24	47.94	60.6	4.0	24.00	42.41	54.6	4.0	24.00	0.00	---	---	0.00
17.09.24	84.88	61.0	4.0	24.00	76.34	55.0	4.0	24.00	0.00	---	---	0.00
18.09.24	89.34	61.0	4.0	24.00	81.17	55.4	4.0	24.00	0.00	---	---	0.00
19.09.24	87.25	61.0	4.0	24.00	79.06	55.3	4.0	24.00	0.00	---	---	0.00
20.09.24	87.69	61.0	4.0	24.00	78.98	55.3	4.0	24.00	0.00	---	---	0.00
21.09.24	87.50	61.0	4.0	24.00	78.94	55.2	4.0	24.00	0.00	---	---	0.00
22.09.24	87.94	61.0	4.0	24.00	78.94	55.2	4.0	24.00	0.00	---	---	0.00
23.09.24	---	---	---	---	---	---	---	---	---	---	---	---
Итого:	2619.61	61.0	4.0	743.99	2374.53	55.5	4.0	743.99	0.00	---	---	0.00

Показания МКТС (нарастающим итогом)

Дата	Объем V1, м3	Траб V1, ч	Объем V2, м3	Траб V2, ч	Объем V3, м3	Траб V3, ч
23.09.24 24:00	263427.97	104401.61	221743.02	104401.61	0.00	0.00
22.08.24 24:00	260808.36	103657.62	219368.48	103657.62	0.00	0.00
Итого:	2619.61	743.99	2374.53	743.99	0.00	0.00

Отчетный период: 768.00 ч Время откл. эл.-питания: 0.01 ч
 Время работы V1: 743.99 ч Время неисправности V1: 0.00 ч
 Время работы V2: 743.99 ч Время неисправности V2: 0.00 ч
 Время работы V3: 0.00 ч Время неисправности V3: 743.99 ч

Представитель
потребителя: _____

Представитель
поставщика: _____

Распечатано программой MktsPrint, версия: 1.31

