

Ведомость учета расхода воды
за период с 23.12.2024 по 23.01.2025

Потребитель: ООО Мастер
 Адрес объекта: Громовой 105 (первая очередь)
 МКТС: № 002611-2 Версия МКТС: 2.42

Дата	Трубопровод № 1				Трубопровод № 2				Трубопровод № 3			
	Объем V1, м3	Темп. °C	Давл. ати	Вр.раб час	Объем V2, м3	Темп. °C	Давл. ати	Вр.раб час	Объем V3, м3	Темп. °C	Давл. ати	Вр.раб час
23.12.24	86.97	60.0	4.0	24.00	76.88	54.2	4.0	24.00	0.00	---	---	0.00
24.12.24	87.03	64.4	4.0	24.00	76.64	57.8	4.0	24.00	0.00	---	---	0.00
25.12.24	87.69	64.3	4.0	24.00	76.27	57.7	4.0	24.00	0.00	---	---	0.00
26.12.24	86.41	64.3	4.0	24.00	76.61	57.7	4.0	24.00	0.00	---	---	0.00
27.12.24	86.09	64.4	4.0	24.00	76.86	57.7	4.0	24.00	0.00	---	---	0.00
28.12.24	86.91	64.1	4.0	24.00	76.19	57.5	4.0	24.00	0.00	---	---	0.00
29.12.24	87.53	63.4	4.0	24.00	75.52	57.0	4.0	24.00	0.00	---	---	0.00
30.12.24	88.50	61.5	4.0	24.00	73.94	55.5	4.0	24.00	0.00	---	---	0.00
31.12.24	85.22	65.2	4.0	24.00	76.89	58.3	4.0	24.00	0.00	---	---	0.00
01.01.25	84.97	64.5	4.0	24.00	76.25	57.8	4.0	24.00	0.00	---	---	0.00
02.01.25	85.78	63.7	4.0	24.00	76.25	57.1	4.0	24.00	0.00	---	---	0.00
03.01.25	85.97	64.3	4.0	24.00	76.23	57.5	4.0	24.00	0.00	---	---	0.00
04.01.25	85.88	65.0	4.0	24.00	76.31	58.1	4.0	24.00	0.00	---	---	0.00
05.01.25	86.56	63.5	4.0	24.00	76.14	56.9	4.0	24.00	0.00	---	---	0.00
06.01.25	85.84	63.8	4.0	24.00	76.27	57.2	4.0	24.00	0.00	---	---	0.00
07.01.25	86.66	63.0	4.0	24.00	75.73	56.6	4.0	24.00	0.00	---	---	0.00
08.01.25	85.88	63.0	4.0	24.00	75.98	56.5	4.0	24.00	0.00	---	---	0.00
09.01.25	86.09	63.1	4.0	24.00	75.83	56.6	4.0	24.00	0.00	---	---	0.00
10.01.25	86.19	62.6	4.0	24.00	75.77	56.2	4.0	24.00	0.00	---	---	0.00
11.01.25	87.00	61.9	4.0	24.00	75.50	55.7	4.0	24.00	0.00	---	---	0.00
12.01.25	86.06	62.6	4.0	24.00	76.00	56.1	4.0	24.00	0.00	---	---	0.00
13.01.25	86.09	63.0	4.0	24.00	76.30	56.4	4.0	24.00	0.00	---	---	0.00
14.01.25	86.47	63.2	4.0	24.00	76.27	56.7	4.0	24.00	0.00	---	---	0.00
15.01.25	86.13	63.2	4.0	24.00	75.95	56.7	4.0	24.00	0.00	---	---	0.00
16.01.25	84.66	63.5	4.0	24.00	74.59	56.8	4.0	24.00	0.00	---	---	0.00
17.01.25	85.06	62.9	4.0	24.00	74.44	56.4	4.0	24.00	0.00	---	---	0.00
18.01.25	85.22	62.7	4.0	24.00	74.34	56.3	4.0	24.00	0.00	---	---	0.00
19.01.25	84.75	62.6	4.0	24.00	74.81	56.2	4.0	24.00	0.00	---	---	0.00
20.01.25	85.66	62.8	4.0	24.00	74.91	56.4	4.0	24.00	0.00	---	---	0.00
21.01.25	84.47	62.9	4.0	24.00	75.28	56.5	4.0	24.00	0.00	---	---	0.00
22.01.25	85.84	63.0	4.0	24.00	75.19	56.5	4.0	24.00	0.00	---	---	0.00
23.01.25	85.72	62.6	4.0	24.00	75.02	56.3	4.0	24.00	0.00	---	---	0.00
Итого:	2755.28	63.3	4.0	768.00	2425.14	56.8	4.0	768.00	0.00	---	---	0.00

Показания МКТС (нарастающим итогом)

Дата	Объем V1, м3	Траб V1, ч	Объем V2, м3	Траб V2, ч	Объем V3, м3	Траб V3, ч
23.01.25 24:00	274188.31	107353.61	231306.56	107353.61	0.00	0.00
22.12.24 24:00	271433.03	106585.61	228881.42	106585.61	0.00	0.00
Итого:	2755.28	768.00	2425.14	768.00	0.00	0.00

Отчетный период: 768.00 ч Время откл. эл.-питания: 0.00 ч
 Время работы V1: 768.00 ч Время неисправности V1: 0.00 ч
 Время работы V2: 768.00 ч Время неисправности V2: 0.00 ч
 Время работы V3: 0.00 ч Время неисправности V3: 768.00 ч

Представитель
потребителя:



Представитель
поставщика:

Распечатано программой MktsPrint, версия: 1.31

