

Месячная ведомость учёта тепловой энергии и теплоносителя за Январь 2025 на ЦО

(с 21.01.2025 по 20.02.2025)

Потребитель: ДС 20 Абонент: _____
 Адрес потребителя: Каштановая Аллея, 174 Телефон: _____
 Ответственное лицо: _____

Прибор: ТЭСМА-106 Сер.номер: 1215627 Расход 1: 0.150 .. 60.000 м3/ч ДУ 50 мм
 Модель: ТЭСМА-106 Версия ПО: _____

Подача $Q=M(h1 - h2)$ Тхв.дог.=3.0°C

Дата/Время	Q [Гкал]	M1 [тонн]	V1 [куб.м.]	T1 [°C]	T2 [°C]	P1 [ат]	P2 [ат]	Тнар [час]
21.01.2025	2.1992	107.0881	110.0242	77.91	57.41	5.20	3.82	24.00
22.01.2025	2.2096	105.8839	108.7993	78.10	57.28	5.20	3.83	24.00
23.01.2025	2.1591	105.4337	108.2991	77.55	57.12	5.18	3.83	24.00
24.01.2025	1.9807	117.4112	120.3451	74.06	57.23	5.18	3.84	24.00
25.01.2025	1.7511	113.0706	115.7924	72.60	57.15	5.19	3.86	24.00
26.01.2025	1.7181	119.3918	122.2103	71.85	57.50	5.25	3.84	24.00
27.01.2025	1.8416	146.2648	149.7230	71.92	59.36	5.23	3.84	24.00
29.01.2025	3.6859	282.4644	289.1569	72.03	58.61	5.22	3.82	48.00
30.01.2025	1.8531	141.6096	144.9544	71.88	58.83	5.29	3.84	24.00
31.01.2025	1.8433	131.4720	134.5919	72.05	58.07	5.19	3.83	24.00
01.02.2025	1.7488	104.8760	107.4576	73.46	56.82	5.10	3.89	24.00
02.02.2025	1.8568	101.4332	104.0717	75.71	57.44	5.16	3.89	24.00
03.02.2025	2.0732	104.2995	107.0615	76.46	56.62	5.14	3.89	24.00
04.02.2025	1.9797	116.0457	118.9514	74.14	57.12	5.17	3.87	24.00
05.02.2025	2.0088	113.5538	116.4182	74.43	56.78	5.21	3.86	24.00
06.02.2025	1.8853	128.5411	131.5920	72.00	57.37	5.18	3.81	24.00
07.02.2025	2.0599	112.6404	115.5441	75.31	57.07	5.15	3.79	24.00
08.02.2025	2.0888	99.4204	102.2943	80.21	59.25	5.19	3.79	24.00
09.02.2025	2.1392	97.4545	100.3908	82.04	60.15	5.20	3.83	24.00
10.02.2025	2.3881	97.1922	100.2230	83.66	59.14	5.13	3.84	24.00
11.02.2025	2.4182	96.9383	99.9574	83.59	58.70	5.13	3.85	24.00
12.02.2025	2.3502	96.2151	99.1524	82.67	58.30	5.10	3.86	24.00
13.02.2025	2.3261	96.5251	99.4507	82.34	58.29	5.10	3.84	24.00
14.02.2025	2.2998	97.9462	100.8566	81.43	58.00	5.13	3.85	24.00
15.02.2025	2.1334	95.6235	98.4996	81.95	59.69	5.18	3.87	24.00
16.02.2025	2.1291	93.5739	96.4229	82.58	59.88	5.18	3.92	24.00
17.02.2025	2.2770	97.4815	100.3744	81.38	58.07	5.15	3.87	24.00
18.02.2025	2.2479	99.7380	102.6196	80.19	57.70	5.19	3.86	24.00
19.02.2025	2.2341	99.8981	102.7729	80.03	57.71	5.19	3.86	24.00
20.02.2025	2.3162	95.7610	98.6714	82.47	58.34	5.13	3.86	24.00
Итого:	64.2021	3415.2477	3506.6789	77.53	58.03	5.18	3.85	744.00

Отч.пер Нараб. Gmin Gmax dTmin Эл.пит. Проч.ав.
 Т [ч] 744.00 = 744.00 + 0.00 + 0.00 + 0.00 + 0.00 + 0.00
 Q [Гкал] 64.2021 = 64.2021 + 0.0000 + 0.0000 + 0.0000 + 0.0000 + 0.0000

Нарастающим итоном на:	Q [Гкал]	M1 [тонн]	V1 [куб.м.]	Тнар [час]
21.01.2025	44.2505	2543.8277	2608.3153	566.60
20.02.2025	108.4527	5959.0754	6114.9943	1310.60
Итого:	64.2021	3415.2477	3506.6789	744.00

(<) параметр < min
 (>) параметр > max
 (X) обрыв датчика
 (T) delta_t < min
 (R) перезапуск
 (C) коррекция часов
 (#) электропитание
 (E) функц.отказ



20.02.2025 Подпись _____

